


SECTION

NOTES

- 1 FORMS SHALL BE TRUE TO LINE AND GRADE AND SECURELY STAKED.
- 2 3/8" OR 1/2" x 2" DUMMY JOINTS SHALL BE PLACED ON 10 FOOT CENTERS. JOINT SPACING MAY VARY (IN A CONSISTENT MANNER, 10' ±1') TO AVOID SHORT (<5') SEGMENTS.
- 3 FULL-DEPTH EXPANSION JOINTS SHALL BE PLACED AT POINTS OF TANGENCY ON STREETS, ALLEYS AND DRIVEWAY RETURNS.
- 4 ALL JOINTS SHALL BE CLEAN AND EDGED.
- 5 CONCRETE SHALL BE CEMENT CONCRETE, CLASS 4000 FROM AN APPROVED SUPPLIER.
- 6 FINISH SHALL BE LIGHT BROOM FINISH.
- 7 THE FINISHED CURB SHALL BE SPRAYED WITH A TRANSPARENT CURING COMPOUND AND COVERED BY WATERPROOF PAPER OR PLASTIC MEMBRANE IN THE EVENT OF RAIN OR OTHER UNSUITABLE WEATHER. CURING TIME SHALL BE A MINIMUM OF 72 HOURS.
- 8 ALL CURB AND GUTTER SHALL BE PLACED ON A MIN OF 4" OF CRUSHED SURFACING TOP COURSE.
- 9 FOR ANY CURB GRADE LESS THAN 0.8% (0.0080 FT/FT), INCLUDING CURB RETURNS, A PROFESSIONAL LAND SURVEYOR SHALL VERIFY THAT THE CURB FORMS OR STRING LINES ARE AT THE GRADES NOTED ON THE APPROVED PLANS PRIOR TO PLACEMENT OF CONCRETE.



City of Covington
 Public Works
 Community Development



CONCRETE CURB AND GUTTER

This document has been signed electronically in accordance with WAC 196-23-070 and Chapter 19.34 RCW. Unauthorized alteration of any of the information on this document will invalidate the document, my certification and signature.

323

Revision Date
July 2009