

DETAIL NOTES

The drywell barrel section(s) shall be fabricated and installed in accordance with WSDOT standard specifications 7-05 and 9-12.7.

Seepage port orientation varies among manufacturers.

Precast cone section may be eccentric or concentric.

Gravel backfill shall be in accordance with WSDOT standard specification 9-03.12(5). Typical quantity for a single-depth drywell: 15 CY, for a double-depth: 35 CY.

Underground drainage geotextile fabric shall be of moderate survivability, as outlined in WSDOT standard specification 9-33, Class A.

For minor adjustments, concrete brick shall be used. Adjustment sections, brick and frame shall be mortared in place.


Stormwater treatment facilities must precede a drywell, when pollution generating surfaces contribute to the runoff.



City of Covington

Public Works

Community Development



DRYWELL

718

This document has been signed electronically in accordance with WAC 196-23-070 and Chapter 19.34 RCW. Unauthorized alteration of any of the information on this document will invalidate the document, my certification and signature.

Revision Date
October 2009