

## SECTION

### DETAIL NOTES

A Type 1L Catch Basin shall be used for 6" and 8" diameter pipes (see Standard Detail 715). Refer to Standard Detail 734 for larger diameter pipes.

The maximum depth from the finished grade to the lowest pipe invert shall be 5 feet.


All joints shall be grouted, inside and out, after the basin, separator and frame have been installed.



City of Covington

Public Works

Community Development



## FLOATABLE MATERIAL SEPARATOR 6" OR 8" PIPE

This document has been signed electronically in accordance with WAC 196-23-070 and Chapter 19.34 RCW. Unauthorized alteration of any of the information on this document will invalidate the document, my certification and signature.

# 733

Revision Date  
October 2009