



DETAIL NOTES

Vault dimensions and materials to be in accordance with approved drainage report.

Baffles and weir shall be of corrosion resistant materials, such as fiberglass reinforced plastic, precast concrete or steel that has been factory coated with epoxy, polyurethane or urethane. Galvanized steel is not acceptable.

	<p>City of Covington</p> <hr/> <p>Public Works</p> <hr/> <p>Community Development</p>		<p>OIL / WATER SEPARATOR</p> <p>API VAULT - SAMPLE</p> <p><small>This document has been signed electronically in accordance with WAC 196-23-070 and Chapter 19.34 RCW. Unauthorized alteration of any of the information on this document will invalidate the document, my certification and signature.</small></p>	<p>738</p> <hr/> <p>Revision Date January 2010</p>
--	--	--	---	---