

## DETAIL NOTES

Refer to the various utility purveyors for their specific utility location requirements.

5' minimum vertical and 10' minimum horizontal separation between public utilities or from private utilities.

Minimum separation requirements from public utilities apply within easements and private property.

Appurtenances, such as manholes, valves, cross pipes and service stubs, are not shown for clarity.

Alignments are subject to change based on locations of storm management facilities. Changes to alignments shown are subject to approval by the City Engineer.


- ① REFER TO THE TYPICAL STREET SECTIONS FOR STREET AND RIGHT-OF-WAY DIMENSIONS. SEE STANDARD DETAILS 202-207.
- ② POWER, CABLE, TELEPHONE, GAS AND OTHER NON-CITY OPERATED UTILITIES MAY BE LOCATED UNDER THE SIDEWALK, UPON APPROVAL OF THE CITY ENGINEER.



City of Covington

Public Works

Community Development



## TYPICAL UTILITY LOCATION

This document has been signed electronically in accordance with WAC 196-23-070 and Chapter 19.34 RCW. Unauthorized alteration of any of the information on this document will invalidate the document, my certification and signature.

**801**

Revision Date  
January 2010